



Republic of the Philippines
LEYTE METROPOLITAN WATER DISTRICT
 A DOH ACCREDITED WATER TESTING LABORATORY
 Accreditation No.: 13-001-08-LW-2
 Rapid Filtration Plant, Brgy. Hibunawon, Jaro, Leyte
 Telefax No. (053) 332-7465/332-7424

BACTERIOLOGICAL TEST RESULT FOR WATER

Name of Client: **Catbalogan Water District**
 Address: **Pier 2, Allen Ave., Catbalogan Samar**

Submitted by: **Zaldy Mahinay**
 Contact No.:

Lab. No.	Sample Source and Address	Date and Time of:			Result of Analysis			Remarks
		Collection	Receipt	Examination	Total (MPN)	Fecal (MPN)	HPC (CFU/ML)	
		June 20, 2014						
14-520	Faucet, San Adres (CWD) Catbalogan , Samar	5:25 AM	3:55 PM	4:35 PM	<1.1	<1.1	31	PASSED
14-521	Faucet, Canlapwas (CWD) Catbalogan , Samar	5:37 AM	3:55 PM	4:40 PM	<1.1	<1.1	96	PASSED
14-522	Faucet, Brgy 10 (CWD) Catbalogan , Samar	5:49 AM	3:55 PM	4:45 PM	<1.1	<1.1	103	PASSED
14-523	Faucet, Brgy 11 (CWD) Catbalogan , Samar	5:59 AM	3:55 PM	4:50 PM	<1.1	<1.1	23	PASSED

Remarks: 1. The results given in this report were obtained at the time of the analysis and refer only to the particular sample submitted.
 2. This result shall not be reproduced unless in full.

Philippine National Standards for Drinking Water (PNSDW)

MPN = Most Probable Number
 CFU = Colony Forming Unit

MPN/100 ml. Total Coliform =
 MPN/100 ml. Fecal Coliform =
 Heterotrophic Plate Count =

Public Water Supplies
 Less than 1.1 or 0
 Less than 1.1 or 0
 Less than 500 CFU/mL

Analyst: *K. Zabala*

KATHERINE S. ZABALA, RMT
 Medical Technologist

Certified Correct:

Rosalinda A. Dumagsa
ROSALINDA A. DUMAGSA
 Quality Control/Assurance Officer

Noted:

Cynthia L. Terrado
CYNTHIA L. TERRADO
 OIC, Div. Mgr., Quality Control