



Republic of the Philippines
LEYTE METROPOLITAN WATER DISTRICT
 A DOH ACCREDITED WATER TESTING LABORATORY
 Accreditation No.: 13-001-08-LW-2
 Rapid Filtration Plant, Brgy. Hibunawon, Jaro, Leyte
 Telefax No. (053) 332-7465/332-7424

BACTERIOLOGICAL TEST RESULT FOR WATER

Name of Client: **CATBALOGAN WATER DISTRICT** Submitted by: ZALDY A. MAHINAY
 Address : Brgy. 4 Allen Avenue, Catbalogan, City Contact No.: 09393289440

Lab. No.	Sample Source and Address	Date and Time of:			Result of Analysis			Remarks
		Collection	Receipt	Examination	Total (MPN)	Fecal (MPN)	HPC (CFU/ML)	
		September 26, 2013						
13-857	Faucet, Canlapwas, Catbalogan, City	5:50 AM	4:00 PM	6:00 PM	1.1	<1.1	42	FAILED
13-856	Faucet, San Pablo, Catbalogan, City	6:04 AM	4:00 PM	6:05 PM	<1.1	<1.1	53	PASSED
13-858	Faucet, Brgy. 2, Catbalogan, City	6:17 AM	4:00 PM	6:10 PM	<1.1	<1.1	27	PASSED
13-860	Faucet, Brgy. 4, Catbalogan, City	6:30 AM	4:00 PM	6:15 PM	1.1	<1.1	58	FAILED
13-861	Faucet, Brgy. 6, Catbalogan, City	6:45 AM	4:00 PM	6:20 PM	<1.1	<1.1	23	PASSED
13-862	Faucet, Brgy. 8, Catbalogan, City	6:58 AM	4:00 PM	6:25 PM	1.1	<1.1	50	FAILED
13-863	Faucet, Brgy. Guinsorongan, Catbalogan, City	7:13 AM	4:00 PM	6:30 PM	1.1	<1.1	41	FAILED
13-864	Faucet, Brgy. 13, Catbalogan, City	7:30 AM	4:00 PM	6:35 PM	<1.1	<1.1	107	PASSED

Remarks: 1. The results given in this report were obtained at the time of the analysis and refer only to the particular sample submitted.

2. This result shall not be reproduced unless in full.

Philippine National Standards for Drinking Water (PNSDW)
 MPN = Most Probable Number
 CFU = Colony Forming Unit

MPN/100 ml. Total Coliform =
 MPN/100 ml. Fecal Coliform =
 Heterotrophic Plate Count =

Refilling Station
 Less than 1.1 or 0
 Less than 1.1 or 0
 Less than 500 CFU/ml

Public Water Supplies
 Less than 1.1 or 0
 Less than 1.1 or 0
 Less than 500 CFU/ml

Analyst: *Rosalina*

KATHERINE S. ZABALA, RMT
 Medical Technologist

Certified Correct:

Rosalinda A. Dumagsa
ROSALINDA A. DUMAGSA
 Quality Control/Assurance Officer

Noted: *Cynthia L. Terrado*

CYNTHIA L. TERRADO
 OIC, Div. Mgr., Quality Control